



Republic of the Philippines  
Department of Health

**CENTRAL OFFICE BIDS AND AWARDS COMMITTEE**

**BID BULLETIN NO. 3**

09 January 2024

**SUPPLY, DELIVERY, INSTALLATION AND TESTING OF INTERMEDIATE DISTRIBUTION FRAME (IDF) UNINTERRUPTIBLE POWER SUPPLY (UPS) FOR DOH CENTRAL OFFICE BUILDINGS  
IB No. 2024-157**

This Bid Bulletin is being issued to announce the new schedule of Submission and Opening of Bids, to clarify the issues and concerns raised by prospective bidders during and after the Pre-Bidding Conference held last 13 December 2023, and to amend or modify the bidding documents posted in the PhilGEPS and DOH websites for the above-mentioned project. This Bid Bulletin shall form an integral part of the bidding documents. Listed below are the corresponding modifications/changes, to wit:

**A. New Schedule of Activity:**

ACTIVITY	FROM	TO	VENUE
Submission and Opening of Bids	27 December 2023; 9:00 AM	<b>17 January 2024; 9:00 AM</b>	COBAC Conference Room., Ground Floor, Bldg. No. 6, Department of Health, San Lazaro Compound, Sta. Cruz, Manila and through video conferencing via Cisco WebEx

**B. Clarification on the Issues and Concerns during the Pre-Bidding Conference:**

PARTICULARS	ISSUES AND CONCERNS	KMITS RESPONSE
Schedule of Delivery	Request for 90 calendar days	No changes on this requirement.
The Prospective Bidder shall supply, deliver, install, and configure the UPS. It shall include supply & installation of input and output circuit breakers, cables, lugs, conduits, fittings, and rough-ins.	Request to delete supply & installation of input and output circuit breakers, cables, lugs, conduits, fittings, and rough-ins	This should be changed and read as:  The Prospective Bidder shall supply, deliver, install, and configure the UPS. <b>It shall include supply &amp; installation of input and output, cables, lugs, conduits, fittings, and rough-ins.</b>
<b>Features and Specification:</b> f.) The UPS Management should be capable of integrating with the existing Data Center Management Console	What is the existing UPS Management?	This should be changed and read as:  f.) The UPS must have management system or console.

**C. End-User's Response to the queries raised by Prospective Bidder's (PBs):**

PARTICULARS	QUERIES	KMITS RESPONSE
<b>POWERCRAFT SOLUTIONS AND DATA INFRASTRUCTURE, INC. (PSDII)</b>		
<p><b>II. Warranty period and Services:</b>  <b>C. Technical Support</b>            1. The winning contractor must have Certified technical support engineers/technical staff, who are regular and locally based employees.</p>	<p>1. We would like to clarify if you are specifically referring on the following certifications which were normally requires on similar projects:</p> <ul style="list-style-type: none"> <li>• At least one (1) Safety Officer employed to the bidder for at least 2 years.</li> <li>• At least one (1) registered Electrical Engineer employed to the bidder for at least 2 years.</li> <li>• Certified Data Centre Professional (CDCP) employed to the bidder for at least 2 years.</li> </ul> <p>Since this is Power/Electrical Critical equipment above personnel requirements will ensure that prospective bidder has the Expertise, Safety, and Quality of work during installation, and maintenance of UPS Equipment.</p>	<p>This is DOH minimum requirement. The prospective bidders may include registered Electrical Engineer, Certified Data Centre Professional, and other relevant certifications to ensure that deployment and installation of their propose UPS is based on industry and safety standard, will not cause fire and damage to equipment.</p>
<p><b>Technical Specifications</b>  <b>II. Warranty period and Services:</b>  <b>C. Technical Support</b>            d. Unresolved issues or problems shall be service on-site. Once on-site, the service provider/or supplier must repair the malfunctioning UPS that includes hardware module, firmware and other embedded peripherals to make it operational again, free of any charge</p>	<p>2. Would it be possible for the DOH to require that the bidder submit an ISO 9001:2015 Certification of the Manufacturer of the brand being offered showing the site address within the Philippines to ensure easy access and availability of replacement of parts within the warranty period and its after-sales support and services?</p>	<p>Yes, the TWG will consider requiring the Prospective Bidder to provide an ISO 9001:2015 Certification from the manufacturer of the proposed UPS.</p> <p>The TWG will include this requirement under C. Technical Support and read as:</p> <p><b>4. The PB must have a valid and current ISO 9001:2015 Certification from the manufacturer of the proposed UPS.</b></p>
<p><b>Technical Specifications</b>            III. Additional requirements to be in the Technical Specifications</p>	<p>3. Would it be possible for the DOH to require that the bidder will provide three (3)-Tier support with local</p>	<p>This is DOH minimum requirement. The prospective bidders may include registered Electrical</p>

PARTICULARS	QUERIES	KMITS RESPONSE
<p>Form arranged, numbered, and tabbed as enumerated below: 4. Certification from prospective or Supplier manufacturer.</p>	<p>office and local hotline numbers speaking the local language to ensure that the communication between the DOH and the support for ease of communication and support? This ensures that during the 10-15 years life cycle of the UPS, the DOH is ensured to have the proper and <b>AVAILABLE</b> Technical support and services during the equipment life span. In the event, that the bidder might be affected by the market crisis, DOH must be sure of available support needed through its Distributor and Manufacturer which must have a local presence in the Philippines.</p>	<p>Engineer, Certified Data Centre Professional, and other relevant certifications to ensure that deployment and installation of their propose UPS is based on industry and safety standard, will not cause fire and damage to equipment.</p>
<p><b>Single Largest Completed Contract (SLCC)</b> Section II. Instructions to Bidders under Item 5.3 that the Bidder must have a completed single contract that is similar to this Project, equivalent to at least fifty percent (50%) of the ABC.</p>	<p>4. We would like to clarify if the Similar contact is the same capacity or the Higher capacity of UPS to ensure technical expertise and experience of the bidder implementing this project. The lower capacity of UPS is plug-and-play only and does not require electrical Systems and far from this requirement.</p>	<p>The SLCC requirement must be the same with UPS technical specification of 2000VA.</p>
<b>LSI LEADING TECHNOLOGIES INC.</b>		
<p><b>Technical Specifications:</b> c) ii. Recharge Time: 3.90 mins at full load</p>	<p>5. The Recharge time requirements are confusing. There is no recharge time of 3.9 min at full load. Can we correct the specification to - Recharge time: 3 hours to 90%? Because this is standard Recharge time all brand of 2000VA UPS and also delete the word-at full load.</p>	<p>This is a typographical error and should be read as: <b>ii. Recharge Time: Recharge Time: 3 hours charging time at 90 to 100%</b></p>
<p><b>Warranty and Services</b></p>	<p>Please confirm the Warranty for battery</p>	<p>This is a typographical error. It should be changed and read as:  Three (3) years warranty on</p>

PARTICULARS	QUERIES	KMITS RESPONSE
		parts, labor and services. Day 1 of warranty shall only start after the issuance of the Certificate of Completion and Acceptance.

**D. Changes in Section VII. Technical Specifications:**

FROM	TO
<p><b>I. Detailed Technical Specifications:</b> The Prospective Bidder shall supply, deliver, install, and configure the UPS. It shall include supply &amp; installation of input &amp; output <del>circuit breakers</del>, cables, lugs, conduits, fittings, and rough-ins.</p>	<p><b>I. Detailed Technical Specifications:</b> The Prospective Bidder shall supply, deliver, install and configure the UPS. It shall include supply and installation of input and output circuit breakers, cables, lugs, conduits, fittings, and rough-ins.</p>
<p style="text-align: center;">xxx</p> <p>c) Battery</p> <p style="text-align: center;">xxx</p> <p style="padding-left: 40px;">ii. Recharge Time: 3.90 min at full load</p> <p style="text-align: center;">xxx</p>	<p style="text-align: center;">xxx</p> <p>c) Battery</p> <p style="text-align: center;">xxx</p> <p style="padding-left: 40px;"><b>ii. Recharge Time: 3 hours charging time at 90 to 100%</b></p> <p style="text-align: center;">xxx</p>
<p><b>II. Warranty Period and Services:</b></p> <p>A. Three (3) years warranty on <del>site</del> parts, labor and services. Day 1 of warranty shall only start after the issuance of the Certificate of Completion and Acceptance.</p> <p style="text-align: center;">xxx</p> <p>C. Technical Support:</p> <p style="text-align: center;">xxx</p>	<p><b>II. Warranty Period and Services:</b></p> <p>A. Three (3) years warranty on parts, labor and services. Day 1 of warranty shall only start after the issuance of the Certificate of Completion and Acceptance.</p> <p style="text-align: center;">xxx</p> <p>C. Technical Support:</p> <p style="text-align: center;">xxx</p> <p><b>4. The PB must have a valid and current ISO 9001:2015 Certification from the manufacturer of the proposed UPS.</b></p>
<p><b><u>III. Additional requirements to be in the Technical Specifications Form arranged, numbered, and tabbed as enumerated below:</u></b></p> <p style="text-align: center;">xxx</p> <p style="text-align: center;">xxx</p>	<p><b><u>III. Additional requirements to be in the Technical Specifications Form arranged, numbered, and tabbed as enumerated below:</u></b></p> <p style="text-align: center;">xxx</p> <p><b>4. Valid and current ISO 9001:2015 Certification from the manufacturer of the proposed UPS.</b></p> <p style="text-align: center;">xxx</p>

**Attached are the revised Technical Specifications and Checklist of Technical and Financial Documents, for the Prospective Bidders' reference and use.**

All other provisions of the bidding documents which are not affected shall remain in force and in effect.

For guidance and information of all concerned.

*SGD.*

**ABDULLAH B. DUMAMA JR., MD, MPA, CESO I**

Undersecretary of Health

Chairperson, COBAC-B

# Technical Specifications

Republic of the Philippines  
Department of Health

## TECHNICAL SPECIFICATIONS

<b>Item No. 1</b>	<b>Supply, Delivery, Installation and Testing of Intermediate Distribution Frame (IDF) Uninterruptible Power Supply (UPS) for DOH Central Office Buildings</b>	Qty./ Unit	<b>1 lot</b>
Name of Manufacturer:		Country of Origin:	
Brand:		Model (if applicable):	
ABC: PhP1,621,000.00			
<b>PURCHASER'S SPECIFICATION</b>		<b>STATEMENT OF COMPLIANCE</b>	
<p><b>I. Detailed Technical Specifications:</b> The Prospective Bidder shall supply, deliver, install and configure the UPS. It shall include supply and installation of input and output, cables, lugs, conduits, fittings, and rough-ins.</p> <p><b>UPS 2000 VA (16 units)</b></p> <p>1. Technical Specifications:</p> <p style="margin-left: 20px;">a) Input AC</p> <p style="margin-left: 40px;">i. Nominal Frequency: 50/60Hz</p> <p style="margin-left: 40px;">ii. Frequency Range: 40 to 70H</p> <p style="margin-left: 40px;">iii. Input Voltage: 220/230/240Vac Single Phase</p> <p style="margin-left: 40px;">iv. Power Factor: &gt; 0.99 at full load &amp; &gt; 0.98 at half load</p> <p style="margin-left: 20px;">b) Output AC</p> <p style="margin-left: 40px;">i. Nominal Frequency: 50hz/60Hz</p> <p style="margin-left: 40px;">ii. Output Voltage: 220/230/240, Single Phase</p> <p style="margin-left: 40px;">iii. Output power factor: Unity</p> <p style="margin-left: 20px;">c) Battery</p> <p style="margin-left: 40px;">i. Type: non-spillable, lead acid</p> <p style="margin-left: 40px;">ii. Recharge Time: <b>3 hours charging time at 90 to 100%</b></p> <p style="margin-left: 20px;">d) Installation mode: Rack mountable</p>			

Republic of the Philippines  
Department of Health

**TECHNICAL SPECIFICATIONS**

<b>Item No. 1</b>	<b>Supply, Delivery, Installation and Testing of Intermediate Distribution Frame (IDF) Uninterruptible Power Supply (UPS) for DOH Central Office Buildings</b>	Qty./ Unit	<b>1 lot</b>
Name of Manufacturer:		Country of Origin:	
Brand:		Model (if applicable):	
ABC: PhP1,621,000.00			
<b>PURCHASER'S SPECIFICATION</b>		<b>STATEMENT OF COMPLIANCE</b>	
<p>2. Features and Specifications:</p> <ul style="list-style-type: none"> <li>a) The UPS should have the hot swappable battery configuration</li> <li>b) The UPS shall have built-in protection against surges, spikes, sags, outages, noise, frequency deviation, transient, under voltage, over voltage, and over current from the AC source</li> <li>c) The UPS should have an automatic static bypass that will automatically transfer the load during UPS internal fault, overload, or temperature</li> <li>d) The UPS should have a built-in RJ-45 port for SNMP monitoring and Web Management</li> <li>e) The UPS should have a communication card that shall provide Web access, environmental sensor data, and third-party customer protocols for the UPS and manage a wide range of operating parameters, sending data over ethernet networks via secure HTTPS protocol and alarms and notifications via SNMP traps.</li> <li>f) The UPS Management should be capable of integrating with the existing Datacenter Management console</li> <li>g) The UPS batteries should be suitable for high efficient discharge applications. It should support at least for more than 260 cycles at 100% discharge</li> <li>h) The battery cabinet of the UPS should</li> </ul>			

Republic of the Philippines  
Department of Health

**TECHNICAL SPECIFICATIONS**

<b>Item No. 1</b>	<b>Supply, Delivery, Installation and Testing of Intermediate Distribution Frame (IDF) Uninterruptible Power Supply (UPS) for DOH Central Office Buildings</b>	Qty./ Unit	<b>1 lot</b>
Name of Manufacturer:		Country of Origin:	
Brand:		Model (if applicable):	
ABC: PhP1,621,000.00			
<b>PURCHASER'S SPECIFICATION</b>		<b>STATEMENT OF COMPLIANCE</b>	
<p style="text-align: center;">be rack-mountable type</p> <p>i) The UPS LCD display</p> <p style="margin-left: 40px;">i. should be capable, allowing the user to operate and control the UPS checking parameters as well as UPS and battery status</p> <p style="margin-left: 40px;">ii. should be able to store and retrieve up to 2000 events/ alarm for reference and diagnosis</p> <p style="margin-left: 40px;">iii. shall be auto-rotatable to vertical or horizontal mode and vice-versa, depending on installation method (rack or tower)</p>			
<p><b>II. Warranty Period and Services:</b></p> <p>A. Three (3) years warranty on parts, labor and services. Day 1 of warranty shall only start after the issuance of the Certificate of Completion and Acceptance.</p> <p>B. Return Merchandise Authorization (RMA): Provide an immediate RMA or backup unit at any time the UPS is not working or under repair within the warranty period.</p> <p>C. Technical Support:</p> <ol style="list-style-type: none"> <li>1. The winning bidder must be certified technical support engineers/technical staff, who are regular and locally based employees.</li> <li>2. Maintenance and technical support available locally</li> <li>3. Helpdesk supports 24/7 including holidays. <ol style="list-style-type: none"> <li>a. Single point of contact</li> <li>b. Support by phone, text, email or other online/electronic means</li> <li>c. Initial response is to address issue through step-by-step instructions and guidance</li> </ol> </li> <li>d. Unresolved issues or problems shall be service on-site. Once on-site, the service provider/ or supplier must repair the malfunctioning UPS including hardware module, firmware and other embedded peripherals to make it operational again, free of any charge.</li> </ol>			



Republic of the Philippines  
Department of Health

**TECHNICAL SPECIFICATIONS**

<b>Item No. 1</b>	<b>Supply, Delivery, Installation and Testing of Intermediate Distribution Frame (IDF) Uninterruptible Power Supply (UPS) for DOH Central Office Buildings</b>	Qty./ Unit	<b>1 lot</b>
Name of Manufacturer:		Country of Origin:	
Brand:		Model (if applicable):	
ABC: PhP1,621,000.00			
<b>PURCHASER'S SPECIFICATION</b>		<b>STATEMENT OF COMPLIANCE</b>	

**4. The PB must have a valid and current ISO 9001:2015 Certification from the manufacturer of the proposed UPS.**

**III. Additional requirements to be in the Technical Specifications Form arranged, numbered, and tabbed as enumerated below:**

1. Original Brochure or downloaded from the internet and other manufacturer's un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data, as appropriate for cross referencing statement of compliance to the technical specification in accordance to what is indicated in the technical specification of the bidding documents;
2. Warranty proposal for all the UPS;
3. The bidder shall submit any of the following whichever is applicable:
  - a. If the bidder is the manufacturer, certificate that the bidder manufactures the products/item; or
  - b. If the bidder is an Exclusive/Authorized Distributor or Dealer of the products/items, a Certificate or Contract from the manufacturer or importer must be provided as proof that the bidder is an Exclusive/Authorized Distributor or Dealer of the products/items; or
  - c. If the bidder is an agent of the exclusive distributor or dealer, the following must be provided:
    - i. Certificate or Distributor/Dealership Agreement by the Manufacturer with the distributor or dealer; and
    - ii. Certificate or Contract/Dealership Agreement between the distributor/dealer and the bidder
4. **Valid and current ISO 9001:2015 Certification from the manufacturer of the proposed UPS.**
5. Certification from Prospective Bidder or Supplier or Manufacturer:
  - a. Certification that the supplier shall issue a Service Support Certificate upon delivery,

Republic of the Philippines  
Department of Health

**TECHNICAL SPECIFICATIONS**

<b>Item No. 1</b>	<b>Supply, Delivery, Installation and Testing of Intermediate Distribution Frame (IDF) Uninterruptible Power Supply (UPS) for DOH Central Office Buildings</b>	Qty./ Unit	<b>1 lot</b>
Name of Manufacturer:		Country of Origin:	
Brand:		Model (if applicable):	
ABC: PhP1,621,000.00			
<b>PURCHASER'S SPECIFICATION</b>		<b>STATEMENT OF COMPLIANCE</b>	
<p>inspection and acceptance as well as one basis for payment.</p> <p>b. Certification from the manufacturer or local exclusive distributor that the warranty shall not be affected with a change of dealer;</p> <p>c. Certification that the supplier has the capacity for corrective and preventive maintenance of the UPS; and that maintenance and technical support staff and engineers must be available locally under its direct employment and supervision and have the experience and training to all staff or engineers.</p> <p>6. Certification from the manufacturer or main authorized distributor in the Philippines that all proposed item will not reach its END-OF- LIFE (products) and END-OF-SUPPORT (services) until its warranty period.</p> <p>7. Sworn Statement using the prescribed form.</p>			

Signature over Printed Name

*[date of signing]*

In the capacity of:

Duly authorized to sign bid for and on behalf of:

*[title or other appropriate designation]*

*[Name of Company]*

*[Complete office address] [Contact No.]*

*[Fax No.] [Email Address]*

# Checklist of Technical and Financial Documents Arranged numbered and tabbed as it appears below:

## I. TECHNICAL COMPONENT ENVELOPE

### *Class “A” Documents*

#### Legal Documents

- (a) Valid PhilGEPS Registration Certificate (Platinum Membership) (all pages) in accordance with Section 8.5.2 of the IRR;

#### *Technical Documents*

- (b) Statement of the prospective bidder of all its ongoing government and private contracts, including contracts awarded but not yet started, if any, whether similar or not similar in nature and complexity to the contract to be bid; **and**
- (c) Statement of the bidder’s Single Largest Completed Contract (SLCC) similar to the contract to be bid, except under conditions provided for in Sections 23.4.1.3 and 23.4.2.4 of the 2016 revised IRR of RA No. 9184, within the relevant period as provided in the Bidding Documents; **and**
- (d) Original copy of Bid Security. If in the form of a Surety Bond, submit also a certification issued by the Insurance Commission;
- or**
- Original copy of Notarized Bid Securing Declaration; **and**
- (e) Conformity with the Technical Specifications, and Schedule of Requirements which may include production/delivery schedule, manpower requirements, and/or after-sales/parts, if applicable; **and**
- (f) Original duly signed Omnibus Sworn Statement (OSS);
- and** if applicable, Original Notarized Secretary’s Certificate in case of a corporation, partnership, or cooperative; or Original Special Power of Attorney of all members of the joint venture giving full power and authority to its officer to sign the OSS and do acts to represent the Bidder.

#### Financial Documents

- (g) The prospective bidder’s computation of Net Financial Contracting Capacity (NFCC);
- or**
- A committed Line of Credit from a Universal or Commercial Bank in lieu of its NFCC computation.

### *Class “B” Documents*

- (h) If applicable, a duly signed joint venture agreement (JVA) in case the joint venture is already in existence;
- or**
- duly notarized statements from all the potential joint venture partners stating that they will enter into and abide by the provisions of the JVA in the instance that the bid is successful.

Other documentary requirements under RA No. 9184 (as applicable)

- (i) [For foreign bidders claiming by reason of their country's extension of reciprocal rights to Filipinos] Certification from the relevant government office of their country stating that Filipinos are allowed to participate in government procurement activities for the same item or product.
- (j) Certification from the DTI if the Bidder claims preference as a Domestic Bidder or Domestic Entity.

**II. FINANCIAL COMPONENT ENVELOPE**

- (a) Original of duly signed and accomplished Financial Bid Form; **and**
- (b) Original of duly signed and accomplished Price Schedule

**III. ADDITIONAL REQUIREMENTS TO BE ATTACHED IN TECHNICAL SPECIFICATIONS FORM:**

- 1. Original Brochure or downloaded from the internet and other manufacturer's un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data, as appropriate for cross referencing statement of compliance to the technical specification in accordance to what is indicated in the technical specification of the bidding documents;
- 2. Warranty proposal for the all the UPS;
- 3. The bidder shall submit any of the following whichever is applicable:
  - a. If the bidder is the manufacturer, certificate that the bidder manufactures the products/item; or
  - b. If the bidder is an Exclusive/Authorized Distributor or Dealer of the products/items, a Certificate or Contract from the manufacturer or importer must be provided as proof that the bidder is an Exclusive/Authorized Distributor or Dealer of the products/items; or
  - c. If the bidder is an agent of the exclusive distributor or dealer, the following must be provided:
    - i. Certificate or Distributor/Dealership Agreement by the Manufacturer with the distributor or dealer; and
    - ii. Certificate or Contract/Dealership Agreement between the distributor/dealer and the bidder
- 4. **Valid and current ISO 9001:2015 Certification from the manufacturer of the proposed UPS.**
- 5. Certification from Prospective Bidder or Supplier or Manufacturer:
  - a. Certification that the supplier shall issue a Service Support Certificate upon delivery, inspection and acceptance as well as one basis for payment;
  - b. Certification from the manufacturer or local exclusive distributor that the warranty shall not be affected with a change of dealer;

- c. Certification that the supplier has the capacity for corrective and preventive maintenance of the UPS; and that maintenance and technical support staff and engineers must be available locally under its direct employment and supervision and have the experience and training to all staff or engineers.
- 6. Certification from the manufacturer or main authorized distributor in the Philippines that all proposed item will not reach its END-OF- LIFE (products) and END-OF-SUPPORT (services) until its warranty period.
- 7. Sworn Statement using the prescribed form.

Note:

- 1) Please refer <https://doh.gov.ph/sites/default/files/basic-page/COBAC-Sample-Forms.pdf> for the following requirements:
  - a) Sworn Statement;
  - b) Computation of NFCC;
  - c) Manufacturer's Authorization;
  - d) Secretary's Certificate;
  - e) Special Power of Attorney;
  - f) Statement of Ongoing Contracts; and
  - g) Statement of SLCC.
- 2) For the following requirements, please refer to **GPPB Resolution No. 16-2020**:
  - a) Bid Form;
  - b) Price Schedule;
  - c) Bid Securing Declaration; and
  - d) Omnibus Sworn Statement